

**Government of Bihar
Public Health Engineering Department**

DISTRICT :- SAMASTIPUR				DIVISION :- SAMASTIPUR										MONTH:-MAY 2026					REMARKS
S.N.	BLOCK	PANCHAYAT	LOCATION OF SOURCE	PARAMETERS															
				pH	TURB	EC	TDS	TH	Ca	Cl	Mg	Alka.	Fe	T.COI					
1	BITHAN	BELSANDI	VIDYA NIKETAN PUBLIC SCHOOL	7.1	1	258	168	72	18	22	10	88	0.1	-Ve					
Acceptable Limit as per BIS 10500/2012				6.5-8.5	1 NTU	-	500 mg/l	200 mg/l	75 mg/l	250mg/l	30 mg/l	200 mg/l	1.0mg/l						
Permissible Limit* in Absence of Alternate source as per BIS 10500/2012				NR	5 NTU	-	2000 mg/l	600 mg/l	200 mg/l	1000 mg/l	100 mg/l	600 mg/l	NR						

Soni
 19/5/26
 Chemist
 P.H. Division Samastipur
 District P.H.D. Samastipur